

Emfuleni Local Municipality (WSA)

Rand Water (WSP)

Average Blue Drop Score : 72%

Average DWQ Compliance : 99%

Regulatory Impression: While Westonaria Local Municipality is displaying an ability to provide tap water which complies with the health parameters of the national standard, improvement is required in DWQ management. Urgent implementation of operational monitoring at the Vaaloewer Water Treatment Works is required.

Water Supply Systems

Sebokeng, Vaal, Vanderbijlpark, Everton, Sharpeville, Bophelong, Boipatong and Vaaloewer

Blue Drop Report Card

Criteria	Water Supply System
Process Controlling	A
DWQ Monitoring Programme Efficiency	B
Credibility of Sample Analysis	F
Regular submission of DWQ data to DWAF	A
DWQ compliance	A
Responses to DWQ Failures	G
Blue Drop Score	72%
Actual DWQ Compliance with Health Parameters of the National Standard	99%